

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7271-1501:131

Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Edwards Signaling, 8985 Towne Center Parkway, Badenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Model SC1OU-3 ionization smoke detector and Model ECSBU-1 base. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an ionization smoke detector head and base for use with separately listed compatible fire alarm control units.

FORMERLY: 7271-1388:246

XL: 7271-1591:136

*Rev. 05-24-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division